



Department of Public Works  
Infrastructure Services Division

**Ghassan Korban**  
Commissioner of Public Works

**Preston D. Cole**  
Director of Operations

**Jeffrey S. Polenske**  
City Engineer

November 18, 2013

Subject: Official Notice No. 155

Material Recovery Facility  
East Roof Replacement  
1313 West Mount Vernon Avenue  
Milwaukee, Wisconsin 53233

Wednesday, November 27, 2013

Addendum No. 1

Gentlemen:

- A. In regard to our advertisement for the Material Recovery Facility East roof replacement located at 1313 West Mount Vernon Avenue, Milwaukee, Wisconsin 53233 this attached Addendum No. 1 is issued to modify the original documents and is hereby made part of the proposal.
- B. Each bidder shall read the entire addendum. Proposals shall include all items included in this Addendum No. 1.

Very truly yours,

Paul Fredrich, Facilities Manager  
Facilities Development & Management Section



**Official Notice No. 155**

Material Recovery Facility  
East Roof Replacement  
at 1313 West Mount Vernon Avenue  
Milwaukee, Wisconsin 53233

**Addendum No. 1**

IMMEDIATELY UPON RECEIPT OF THE ADDENDUM, PLEASE SIGN THIS  
RECEIPT AND FAX BACK TO DPW- FACILITIES DEVELOPMENT AND  
MANAGEMENT SECTION AT (414) 286-5907.

Company Name

Name

Date

\_\_\_\_\_

**ADDENDUM No. 1**

**November 18, 2013**

Material Recovery Facility  
East Roof Replacement  
1313 West Mount Vernon Avenue  
Milwaukee, Wisconsin 53233

**ON THE Specific Official Notice No. 155**

**CHANGE the Bid date to read:**

The Bid Opening date has been changed. The first page of the Official Notice should read as follows:

**“Seal bids will be opened on Wednesday, November 27, 2013”**

**ON THE DRAWINGS:**

**Modify details A3 and A6 on sheet 400 modify text note as follows:**

Omit “Fill space between existing panel ribs w/ expanded polystyrene insulation” and add  
“Provide 3.5 inch batt insulation with vapor retarder installed facing towards the interior of the structure”.

**Add attached Sheet:**

Add #1-1, Detail A1, Sheet 400, “New Pipe Railing Detail”

**IN THE SPECIFICATIONS:**

**In Section 07 21 00 Part 2 – Products, replace Rigid Insulation with Batt Insulation as follows:**

**BATT INSULATION**

Manufacturers of Glass-Fiber Insulation

CertainTeed Corporation  
Johns Manville Corporation  
Knauf Fiber Glass  
Owens-Corning Corporation

Faced Mineral Fiber Batt Insulation: ASTM C665, Category 1 (member is a vapor barrier), faced with foil-scrim-kraft, foil-scrim, or foil-scrim-polyethylene vapor retarder membrane on one face:

Mineral Fiber Type: Fibers manufactured from glass, slag wool or rock wool.

Thermal Resistance (deg F x h x sq. ft./Btu at 75 deg F)

13 for 3.5 inches thickness  
19 for 6.25 inches thickness  
30 for 9.5 inches thickness

38 for 12.0 inches thickness

**In Section 07 21 00 Part 3 - Execution, Installation of Building Insulation, line 22 replace with:**

Batt Insulation: Install insulation in a single layer between the structural members and the exterior panels. Install insulation over and perpendicular to the structural members with the facing towards the interior of the structure. Care should be taken not to overstretch the insulation material as excess compression can reduce the insulation's thermal performance. All seams should be sealed to help maintain a continuous vapor retarder.


**In Section 07 61 00 Part 2 – Products, omit Underlayment Materials.**

**In Section 07 61 00 Part 3 – Execution, omit Underlayment Installation.**



# NEW PIPE RAILING DETAIL

3" = 1'-0"



© 2013 Plunkett Raysich Architects, LLP

DATE	11-14-15	JOB NUMBER	110413-06
DRAWN BY	SMD	SHEET NUMBER	ADD #1-1

MATERIAL RECOVERY FACILITY - EAST RE-ROOF

1313 WEST MOUNT VERNON AVE.

MILWAUKEE, WI 53233



PLUNKETT RAYSICH  
ARCHITECTS, LLP

intelligent designs. inspired results. | [www.prarch.com](http://www.prarch.com)

11000 west park place milwaukee, wisconsin 53224 t 414 359 3060  
2310 crossroads drive suite 2000 madison, wisconsin 53718 t 608 240 9900  
1613 fruitville road suite 3 sarasota, florida 34236 t 941 348 3618